



# Certificate

www.bsria.co.uk

Certificate No: 40084/5

Issue No: 2

Date of issue: 8 December 2010

This is to certify that

## BSRIA Limited

has Type Tested the emergency smoke ventilator described below in accordance with the test methods contained within BS EN12101-3: 2002, Clauses 5 and 6.1 to 6.7 and has determined that the item met the requirements of the standard for the time and temperature classes listed.

Date of Test	05/09/07
BSRIA Test Item Number	40084B1MAR
<b>Ventilator Details</b>	
Ventilator Supplier	ExcelAir
Ventilator Model	CPC 250-4-S
Ventilator Serial Number	00278
<b>Motor Details</b>	
Motor Manufacturer	WEG
Motor Model	3~90S-4, 1.5 kW
Motor Serial Number	QC20960
<b>Test Conditions</b>	
BS EN 12101-3 Test Class	F300 Unclassified, 300°C, 2 hrs
Application Classes	Un-insulated Smoke reservoir Dual purpose No ducted cooling air required
Test Set-up	Horizontal Immersed Centrifugal fan with motor in airstream
<b>Certificate Details</b>	
Client	ExcelAir
Client Address	Postbus 6153 4000 HD Tiel Netherlands
Date of issue	8 December 2010
Date of expiry	8 December 2013

**Quality Approved** Phil Stonard  
Laboratory Manager  
MicroClimate & Test

Full details are shown in BSRIA Report Number 40084/3, available from the client. To authenticate this certificate, visit [www.bsria.co.uk/certificates](http://www.bsria.co.uk/certificates), or contact BSRIA Limited.